EC Declaration of Conformity (Ex



Manufacturer's Name: Automation Products Group Inc.

> Address: 1025 West 1700 North

> > Logan, UT 84321

Tel: (435) 753-7300 Fax: (435) 753-7490

Email: sales@apgsensors.com Web: www.apgsensors.com

Declares that the product:

Product Name:

HU-L24-IS-nnK-PSIS-Enn-Pnn-Knn-Bnn Pressure Transducer

Conforms to:

ATEX Directive 94/9/EC

- EC Type Examination Certificate: Sira 13ATEX2023

Sira 0518

Sira Certification Service, Rake Lane, Eccleston, Chester, CH4 9JN, England

Description of Equipment or Protective System:

The equipment measures a Pressure and provides a 4-20mA output signal proportional to the measured Pressure.

Series: HU-L24 Series

Conforms to the following Standards

EN 60079-0:2012 EN 60079-26:2007 EN 60079-11:2012

Markings: : ATEX:

Ex II 1G Ex ia IIB T4 Ga (Ta = -40°C to +85°C)

Supplementary Information:

The product described in this Declaration of Conformity complies with the Applicable European Directives and relevant sections of the Applicable International Standards. The signature on this document authorizes the distinctive European mark to be applied to the equipment described.

Authorized Signature: