



E³Point[®] SPECIFICATIONS

Toxic and Combustible Gas Detector Network Platform (BACnet MS/TP, Modbus)

General Specifications					
Uses	Wall or duct-mounted network gas detector for monitoring toxic, oxygen, and combustible gases				
Size	20.56 x 14.90 x 6.72cm (8.09 x 5.87 x 2.65") (H x W x D)				
Power Requirement	24 Vac nominal (17-27Vac), 50/60 Hz, 0.35 A; 24 Vdc nominal (20-38Vdc)				
Relay Output	1 DPDT relay, 5A @ 250Vac; 5A @ 30Vdc				
Communications	RS485 Modbus; BACnet MS/TP master				
Operating Environment	Commercial, indoor, safe area				
Operating Temperature	H ₂ S, NO ₂ , O ₂ , CH ₄ , H ₂ , C ₃ H ₈ : -40 to 50°C (-40 to 122°F) CO: -20 to 50°C (-4 to 122°F)				
Response Time	T90 < 50 seconds With ECLAB T90 < 240 seconds				
Display	8 character, 2 line backlit LCD				
Visual Indicators	Green LED: Power Amber LED 1: Alarm/Fault Amber LED 2: Alarm/Fault				
Audible Alarm	>85 dBA at 3 m (10 ft)				
Accuracy	± 3% of full scale @ 25°C CO only: 5% of reading at 150ppm and 25°C; Long term drift: <5% per year				
Gases Detected, Detection Ranges and Alarm Levels					
Gas	Resolution	Range	Alarm A	Alarm B	Alarm C
CO (Carbon monoxide)	1 ppm	0-250 ppm	25 ppm	100 ppm	225 ppm
H ₂ S (Hydrogen sulfide)	0.1 ppm	0-50 ppm	10 ppm	15 ppm	20 ppms
NO ₂ (Nitrogen dioxide)	0.1 ppm	0-10 ppm	0.7 ppm	2 ppm	9 ppm
O ₂ (Oxygen)	0.1% vol.	0-25% vol.	19.5% vol.	22% vol.	22.5% vol.
H ₂ (Hydrogen)	0.5% LEL	0-100% LEL	25% LEL	50% LEL	90% LEL
CH ₄ (Methane)	0.5% LEL	0-100% LEL	25% LEL	50% LEL	90% LEL
C ₃ H ₈ (Propane)	0.5% LEL	0-100% LEL	25% LEL	50% LEL	90% LEL
Enclosure					
	Polycarbonate				
Certification					
	Standard for Safety for Electrical Equipment for Measurement, Control, and Laboratory Use; Part 1: General Requirements UL 61010-1 2nd Edition, Dated 07/12/2004, With Revisions Through 10/28/2008; Harmonized with CSA C22.2 No. 61010-1-04, Update No. 1 Dated October 2008 (2009); Certified by Intertek to comply with IEC 61010-1:2010 (Third Edition) E ³ Point can be used with the 301C24 to construct a California Title 24 compliant gas detection system.				

Find out more

www.honeywellanalytics.com

Toll free: 1 800 563 2967

Please Note:

While every effort has been made to ensure accuracy in this publication, no responsibility can be accepted for errors or omissions. Data may change, as well as legislation, and you are strongly advised to obtain copies of the most recently issued regulations, standards, and guidelines. This publication is not intended to form the basis of a contract.